



中国认可  
国际互认  
检测  
TESTING  
CNAS L20939

# 检 验 报 告

## Test Report

NO:2025-JAJC-BG2168

委托单位: 港顺阀门有限公司

产品名称: 洒水喷头

型号规格: T-ZSTZ 80-68°C Q5A

检验类别: 型式试验



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

# 注 意 事 项

## REMARKS

- 1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

- 2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

- 3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

- 4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

- 5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

- 6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

- 7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

---

地址：福建省泉州市南安市溪美街道安山路 1 号      电话：0595-86068119

网址：www.jajczx.com      邮箱：jiuantesting@163.com      邮编：362300



# 玖安检测认证有限公司

## 检 验 报 告

NO:2025-JAJC-BG2168

第 1 页 共 5 页

|         |                                                                                                                                 |      |                  |
|---------|---------------------------------------------------------------------------------------------------------------------------------|------|------------------|
| 产品名称    | 洒水喷头                                                                                                                            | 商标   | 港顺               |
| 型号规格    | T-ZSTZ 80-68℃ Q5A                                                                                                               |      |                  |
| 生产者     | 港顺阀门有限公司                                                                                                                        |      |                  |
| 生产企业    | 港顺阀门有限公司                                                                                                                        |      |                  |
| 检验类别    | 型式试验                                                                                                                            |      |                  |
| 生产日期    | 2025 年                                                                                                                          | 到样日期 | 2025 年 09 月 19 日 |
| 样品数量    | 150 只                                                                                                                           | 样品状态 | 完好               |
| 送样地点    | 玖安检测认证有限公司                                                                                                                      | 检验时间 | 2025 年 09 月 20 日 |
| 检验依据    | GB 5135.1-2019 《自动喷水灭火系统 第 1 部分：洒水喷头》                                                                                           |      |                  |
| 检 验 项 目 | 整体要求；接口螺纹；外观与标志；密封结构要求；水压密封和耐水压强度性能；流量系数；布水性能；溅水盘上、下的喷水量；静态动作温度；功能；抗水冲击性能；溅水盘强度；疲劳强度；热稳定性；抗振动性能；抗碰撞性能；抗翻滚性能；耐高温性能；耐盐雾腐蚀性能；抗真空性能 |      |                  |
| 检 验 结 论 | 经检验，所检项目符合 GB 5135.1-2019 标准要求，判定合格                                                                                             |      |                  |
| 备 注     |                                                                                                                                 |      |                  |

批准：陈瑞金

审核：戴少阳

编制：詹其轩

