



中国认可  
国际互认  
检测  
TESTING  
CNAS L20939

# Test Report

NO: 2026-JAJC-BG0593

Client: Jinggong Valve Group Co., Ltd.  
Product Name: Explosion-proof Wet Alarm Valve  
Model & Spec: ZSFZ 100-1.6Q-Ex  
Inspection Category: Entrusted Inspection



Jiu'an Testing and Certification Co., Ltd.

# REMARKS

- 1、 The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.
- 2、 Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.
- 3、 The report is invalid without the signature of the preparer, reviewer, or approver.
- 4、 Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.
- 5、 If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.
- 6、 The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.
- 7、 The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

---

Address: No. 1 Anshan Road, Ximei Street, Nan'an City, Quanzhou, Fujian Province

Phone: 0595-86068119 Website: [www.jajczx.com](http://www.jajczx.com) Email: [jiuantesting@163.com](mailto:jiuantesting@163.com)

Postal Code: 362300






# Test Report

NO:2026-JAJC-BG0593

Page 1 of 3

Product Name	Explosion-proof Wet Alarm Valve	trademark	
Model & Spec	ZSFZ 100-1.6Q-Ex		
Manufacturer	Jingong Valve Group Co., Ltd.		
Manufacturer	Jingong Valve Group Co., Ltd.		
Inspection Category	Entrusted Inspection		
Production Date	the year 2026	Sample Arrival Date	19 March 2026
Sample Quantity	1 set	Sample Status	Intact
Place of Sample Delivery	Jiu'an Testing and Certification Co., Ltd.	Inspection Time	20 March 2026
Inspection Basis	GB 5135.2-2003 Automatic Sprinkler Systems - Part 2: Wet Alarm Valves, Delays and Water Motor Sirens		
Inspection Item	Strength; Leakage and Deformation		
Inspection Conclusion	<p>Upon inspection, the tested items comply with the requirements of GB 5135.2-2003 standard, and the product is judged to be qualified.</p> <p style="text-align: right;">             (Special Seal for Inspection and Testing)            Date of issue: 23 March 2026         </p>		
Remarks			

Approved by: 陈瑞金 Reviewed by: 戴少阳 Prepared by: 陈滔

