



中国认可
国际互认
检测
TESTING
CNAS L20939

Test Report

NO: 2026-JAJC-BG0594

Client: Jinggong Valve Group Co., Ltd.

Product Name: Explosion-proof Deluge Valve

Model & Spec: ZSFM 50-1.6Q-Ex、ZSFM 65-1.6Q-Ex、
ZSFM 80-1.6Q-Ex、ZSFM 100-1.6Q-Ex、
ZSFM 150-1.6Q-Ex、ZSFM 200-1.6Q-Ex

Inspection Category: Entrusted Inspection



Jiu'an Testing and Certification Co., Ltd.

REMARKS

- 1、 The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.
- 2、 Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.
- 3、 The report is invalid without the signature of the preparer, reviewer, or approver.
- 4、 Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.
- 5、 If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.
- 6、 The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.
- 7、 The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

Address: No. 1 Anshan Road, Ximei Street, Nan'an City, Quanzhou, Fujian Province

Phone: 0595-86068119 Website: www.jajczx.com Email: jiuantesting@163.com

Postal Code: 362300







Test Report

NO:2026-JAJC-BG0594

Page 1 of 9

Product Name	Explosion-proof Deluge Valve	trademark	
Model & Spec	ZSFM 50-1.6Q-Ex、ZSFM 65-1.6Q-Ex、ZSFM 80-1.6Q-Ex、ZSFM 100-1.6Q-Ex、ZSFM 150-1.6Q-Ex、ZSFM 200-1.6Q-Ex		
Manufacturer	Jinggong Valve Group Co., Ltd.		
Manufacturer	Jinggong Valve Group Co., Ltd.		
Inspection Category	Entrusted Inspection		
Production Date	the year 2026	Sample Arrival Date	19 March 2026
Sample Quantity	1 each	Sample Status	Intact
Place of Sample Delivery	Jiu'an Testing and Certification Co., Ltd	Inspection Time	21 March 2026
Inspection Basis	GB 5135.5-2018 Automatic Sprinkler Systems - Part 5: Deluge Alarm Valves		
Inspection Item	Valve Body Strength; Leakage and Deformation		
Inspection Conclusion	<p>After inspection, the tested items comply with the requirements of GB 5135.5-2018 standard, and the product is judged to be qualified.</p> <p style="text-align: right;">  (Special Seal for Inspection and Testing) Date of issue: 23 March 2026 </p>		
Remarks			

Approved by: 陈瑞金 Reviewed by: 戴少阳 Prepared by: 陈心同