



中国认可
国际互认
检测
TESTING
CNAS L20939

检验报告

Test Report

NO: 2026-JAJC-BG0687

委托单位：北京市阀门总厂股份有限公司

产品名称：压力开关

型号规格：ZSJY1.6BP-S

检验类别：型式试验

 玖安检测认证有限公司

Jiu'an Testing and Certification Co., Ltd



注 意 事 项

REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

地址：福建省泉州市南安市溪美街道安山路 1 号 电话：0595-86068119

网址：www.jajczz.com 邮箱：jiuantesting@163.com 邮编：362300





玖安检测认证有限公司

检验报告

NO:2026-JAJC-BG0687

第 1 页 共 4 页

产品名称	压力开关	商标	
型号规格	ZSJY1.6BP-S		
生产者	北京市阀门总厂股份有限公司		
生产企业	北京市阀门总厂股份有限公司邯郸分厂		
检验类别	型式试验		
生产日期	2026 年	到样日期	2026 年 03 月 27 日
样品数量	8 只	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2026 年 03 月 30 日至 2026 年 04 月 29 日
检验依据	GB 5135.10-2006 《自动喷水灭火系统 第 10 部分：压力开关》		
检 验 项 目	外观；额定工作压力；动作压力；强度要求；工作可靠性要求；耐湿热要求；耐盐雾腐蚀要求；抗振要求；碰撞要求；绝缘要求；耐电压要求；触点接触电阻；触点数量；连接方式		
检 验 结 论	经检验，所检项目符合 GB 5135.10-2006 标准要求，判定合格。  签发日期：2026 年 04 月 30 日		
备 注	其中 6.13、6.14 项目为 CMA 资质认定范围内，不在 CNAS 认可范围内。		

批准：陈瑞金

审核：戴少阳

编制：陈文辉